

Cooling Formulas

CONVERSION

1 Ton = 12000 Btu/hr

COOLING LOAD REQUIREMENT

Total Cooling Load (Btu/hr) = $4.5 \times \text{CFM} \times (\text{H1} - \text{H2})$

Where:

CFM = Airflow in Cubic Feet Per Minute

H1 = Entering Air Enthalpy (Btu/lbm dry air)

H2 = Leaving Air Enthalpy (Btu/lbm dry air)

Or

Total Cooling Load (Btu/hr) = Sensible Cooling Load (Btu/hr) + Latent Cooling Load (Btu/hr)

Where:

Sensible Cooling Load (Btu/hr) = $\text{CFM} \times \text{Density Factor} \times (\text{T1} - \text{T2})$

Latent Cooling Load (Btu/hr) = $\text{CFM} \times 0.69143 \times (\text{G1} - \text{G2})$

Where:

CFM = Airflow in Cubic Feet Per Minute

Density Factor = $1.08 + \frac{(70 - \text{Blower Temp}) \times .024}{10}$

10

T1 = Entering Air Drybulb Temperature (°F)

T2 = Leaving Air Drybulb Temperature (°F)

G1 = Grains of Moisture of Entering Air = $7000 \times \text{humidity ratio}$ (lbm moisture/lbm of dry air)

G2 = Grains of Moisture of Leaving Air = $7000 \times \text{humidity ratio}$ (lbm moisture/lbm of dry air)

EFFICIENCY CALCULATION

SEER = BTU / W-hr

COST OF COOLING:

Cost of cooling = $\text{BTU/hr} \times \text{hrs of operation} \times \text{electricity cost} (\$/\text{kw-hr}) / (\text{SEER} \times 1000)$